

# Paris Session 2022



## Experience and challenges from zero crossing damped overvoltage test on 525kV cable to TB852

SC B1 Insulated Cables - PS2 - Q5

Martin HENRIKSEN, France



Group Discussion Meeting


© CIGRE 2022

1


© CIGRE 2021

# Experience w. zero crossing damped overvoltage test on 525kV cable system

- Complete 525kV cable system incl. 2 joints & 2 terminations
  - Pre-conditioning loadcycles
  - ~5.7kHz (act. 5.56kHz) with  $n_4 = 15$  (neg. & pos.)
  - ~350Hz (act. 362Hz) with  $n_4 = 4$  (neg. & pos.)



- - - - Decay rate 350Hz
- - - - DOV 350Hz
- - - - Decay rate 6kHz
- - - - DOV 6kHz
- ..... -5%
- ..... +5%
- - - - -115%
- - - - +115%



- Recommendations:**
- Test both low and high freq.
  - Define  $n_4$  per frequency
  - Exact freq. may not be achieved

# Challenge no. 1 – Measure correctly

Offset caused by universal divider


- Offset varies and is frequency dependent

→ All curves to be post-processed individually

- 5.6kHz: → correction 5.9kV – 8.5kV (~1.4%)
- 360Hz → correction 0.7kV – 1.7kV (~0.3%)



→ Relative to 5% limit for  $n_4$ , 1.4% **offset is critical**

→ Risk of non-valid pulses





Recommendations:

- Post-process data for validation
- Define  $n_4$  as minimum in protocol (exact  $n_4$  may not be achieved)




# Challenge no. 2 – Spread in attenuation – defining $n_4$

360Hz:



Little variability in attenuation



- Spread  $U_4 \sim 5\%$
- Spread  $U_5 \sim 9\%$



Recommendations:

- Define  $n_4$  as minimum
- Aim for  $\gg 5\%$  attenuation at  $n_4$

5.6kHz :



High variability in attenuation

- Spread  $U_{15} \sim 25\%$
- Spread  $U_{16} \sim 26\%$
- $n_4$  between 17 and 19

