Paris Session 2022



Criteria for choosing between Transmission SVCs and STATCOMs in Brazil SC B4 – DC Systems and Power Electronics PS 3-1, Question 3-1

Ricardo Tenorio - Brazil



Group Discussion Meeting

© CIGRE 2022

© CIGRE 2021


SVCs vs. STATCOMs in Brazil (1)

• The Brazilian Interconnected Power System (BIPS) is expanded based on transmission auctions and has 42 SVCs and only 1 STATCOM.

- These auctions have SVCs as a reference alternative. However, STATCOMs can be also offered if they fulfill all the technical requirements.
 - Auction technical documents are being adapted to allow fairer competition between SVCs and STATCOMs.
 - Reactive power support in Brazil is defined by the Expansion Planning Authority (EPE) and is studied for integration by the Brazilian System Operator (ONS).
- Investors have some reasons to support SVCs:
 - Higher nationalization of SVC components when compared to STATCOM.
 - Good experience with SVCs in Brazil regarding component replacement, degraded modes, reliability indices, and performance.
 - Some issues with the only STATCOM in operation in Brazil.
 - Nowadays statistics about STATCOM performance only (RAM), in general, are scarce.

Bidders in Brazil don't want to take further risks regarding STATCOMs.
Group Discussion Meeting

SVCs are the reference alternative




© CIGRE 2022

SVCs vs STATCOMs in Brazil (2)

- Auctions Technical Documents will accommodate both technologies in search of more competitiveness. Some suggestion points follow.
 - STATCOMs are also being analyzed to be a possible reference alternative in the same way SVCs are nowadays.
 - According to some manufacturers, for instance, a ±300 Mvar STATCOM may be competitive with a ±300Mvar SVC (2 TCRs +2 TSCs+ HFs, regular configuration in Brazilian transmission auctions).
 - Asymmetrical output ranges may not be the best cost-effective solution to reactive power compensation issues. This usually leads to SVC-based applications. Note that pure STATCOMs are inherently symmetrical.
 - Power loss requirements are met by both technologies.
 - RAM requirements are being carefully established for SVCs/STATCOMs (availability ≥ 99%, STATCOMs IGBT submodules redundancy ≥10%).
 - Low voltage ride-through capabilities are proposed to be differently specified for SVCs and STATCOMs.
 - The overvoltage inductive cycle is the same for both technologies.

Group Discussion Meeting



© CIGRE 2022