

# Paris Session 2022



## Development of dispatching monitoring and control technology based on PMU data SC C2 Power System Operation and Control PS1 Q1.5

Dmitrii Dubinin (Russia)



## How can we define the optimal number of PMU

- optimal number of PMU depends on the DER connection method to the power grid;
- ideal decision – as much as possible;
- real decision – installation a PMU on every feeder connecting the wind farm to the power grid;
- the best scenario is to make PMU cheap and affordable to remove the financial constraints on their installation.